



# A Comparison between commercial Pipeline Fluid-dynamic Codes

## OLGA vs. LEDAFLOW



saipem

## *Presentation Content*

---

- Scope
- Analyzed Pipeline System and Basic Data
- Steady State Simulation – Results and Summary
- Transient Simulation – Results and Summary
- Summary of Main Findings
- Further Developments

# Scope

---

**Scope**

## Scope

---

- The Scope of work is a fluid-dynamic comparison to confront and contrast OLGA (developed by Schlumberger) and Leda Flow (developed by Kongsberg) by simulating deep water Flowline connected via offshore platform to a subsea pipeline. Comparison was performed by selecting pre-defined process variables (such as pressure, temperature, velocity, hold up, etc).
- The aim of the study was to emphasise the reliability of results obtained when using either of two software; i.e. how different the results would be if the simulations were parting from identical input file and would the potential deviations have any impact on the project outcome.
- The steady state analysis was performed using four different fluids, three different flowline and trunkline diameters for three different receiving pressures at the arrival onshore terminal.
- The sensitivity analysis was the base for the transient analyses, namely shut down (and subsequent cool down), depressurization, ramp up, turn down and pigging.
- This work has been jointly performed by **Saipem** (Olga cases' simulation and data processing) and **Streamline** (LedaFlow cases' simulation and data processing).

**Analyzed Pipeline System  
And Basic Data**


## Basic Data – Production HC Fluids

| Fluid            | TAG | EoS  | Critical Point | Cricondembar | Cricondentherm | Water dew point @70bar |
|------------------|-----|------|----------------|--------------|----------------|------------------------|
|                  |     |      | [°C / bara]    | [bara]       | [°C]           | [°C]                   |
| Dry Gas          | GD  | PRp  | -80 / 48.7     | 48.7         | -79.0          | n/a                    |
| Light Condensate | GCL | SRKp | n/a            | 221.0        | +79.0          | n/a                    |
| Multiphase       | GCW | SRKp | 306 / 305      | 313.0        | +465.0         | +225.0                 |
| Oil              | MO  | SRKp | 569 / 80       | 87.0         | +646.0         | n/a                    |

| Fluid | Molar Composition (%) |      |       | Spec. Gravity |       | Viscosity [cP] |     |       |
|-------|-----------------------|------|-------|---------------|-------|----------------|-----|-------|
|       | Gas                   | Oil  | Water | Gas           | Oil   | Gas            | Oil | Water |
| GD    | 100                   | 0.0  | 0.0   | 0.689         | -     | 0.010          | -   | -     |
| GCL   | 99.9                  | 0.1  | 0.0   | 0.767         | 0.883 | 0.011          | 2.2 | -     |
| GCW   | 41.4                  | 24.2 | 34.4  | 0.958         | 0.827 | 0.010          | 3.6 | 1.1   |
| MO    | 14.7                  | 85.3 | 0.0   | 1.540         | 0.939 | 0.009          | 213 | -     |

**Fluid Property files** (i.e. the fluid property tables) have been prepared using PVTsim thermodynamic package for each fluid. The PVT tables were an input to both the fluid-dynamic simulators.


# Basic Data – Used Subsea Pipeline Simulation Scheme



| Material     | Capacity | Conductivity | Density              |
|--------------|----------|--------------|----------------------|
|              | [J/kg-K] | [W/m-K]      | [kg/m <sup>3</sup> ] |
| Carbon Steel | 460      | 50           | 7850                 |
| Concrete     | 880      | 2.1          | 3040                 |
| PE3L         | 1300     | 0.4          | 900                  |
| Soil         | 3000     | 2.5          | 2100                 |
| Contratherm™ | 2200     | 0.186        | 850                  |


| Point ID. | Item                  | Line      | Pipe    | Section | Section Boundary | KP      |
|-----------|-----------------------|-----------|---------|---------|------------------|---------|
| 0         | Closed Inlet Node     | Flowline  | -       | -       | -                | 0       |
| 1         | Source                | Flowline  | PIPE-01 | 1       | -                | 37.7184 |
| 2         | Riser Inlet           | Flowline  | PIPE-23 | -       | 1                |         |
| 3         | Riser Outlet          | Flowline  | PIPE-28 | -       | 1                |         |
| 4         | Leak                  | Flowline  | PIPE-29 | 3       | -                | 9279.98 |
| 5         | Valve / Merge Node    | Flowline  | PIPE-29 | -       | 4                | 9284.87 |
| 6         | Source                | Trunkline | PIPE-01 | 1       | -                | 2.54344 |
| 7         | Riser Inlet           | Trunkline | PIPE-02 | -       | 1                |         |
| 8         | Riser Outlet          | Trunkline | PIPE-04 | -       | 1                |         |
| 9         | Leak                  | Trunkline | PIPE-74 | 2       | -                | 222476  |
| 10        | Valve / Pressure Node | Trunkline | PIPE-74 | -       | 3                | 222480  |

# Basic Data – Flowline Characteristics



| Position |       | Insulation | Concrete | Burial Condition |           | Ambient | OHTC     |
|----------|-------|------------|----------|------------------|-----------|---------|----------|
| From KP  | To KP | Type       | Type     | Type             | Depth [m] | Type    | [W/m2-K] |
| 0.000    | 9.250 | C55-850    | -        | Exposed          | -         | Water   | 3.4      |
| 9.250    | 9.285 | C55-850    | -        | Exposed          | -         | Air     | 3.4      |

# Basic Data – Trunkline Characteristics



| Position |         | Insulation |         | Concrete |         | Burial Condition |           | Ambient | OHTC     |
|----------|---------|------------|---------|----------|---------|------------------|-----------|---------|----------|
| From KP  | To KP   | Type       | WT [mm] | Type     | WT [mm] | Type             | Depth [m] | Type    | [W/m2-K] |
| 0.000    | 0.020   | 3L-PE      | 3.5     | -        |         | Exposed          | -         | Air     | 117.1    |
| 0.020    | 209.330 | 3L-PE      | 3.5     | Yes      | 40      | Exposed          | -         | Water   | 39.6     |
| 209.330  | 218.092 | 3L-PE      | 3.5     | -        | -       | Buried           | 1.0       | Water   | 4.0      |
| 218.092  | 222.460 | 3L-PE      | 3.5     | -        | -       | Buried           | 2.0       | Water   | 3.1      |
| 222.460  | 222.480 | 3L-PE      | 3.5     | -        | -       | Exposed          | -         | Air     | 117.1    |

## Basic Data – Pipeline Size, Flowrate, Arrival Pressure

The following nominal diameters of flowline and trunkline were considered:

- 8" / 24"
- 10" / 32"
- 12" / 36"

| Line      | ND     | OD    | ID    | WT    |
|-----------|--------|-------|-------|-------|
|           | [inch] | [mm]  | [mm]  | [mm]  |
| Flowline  | 8      | 203.2 | 177.8 | 12.70 |
|           | 10     | 254.0 | 222.3 | 15.88 |
|           | 12     | 304.8 | 266.7 | 19.05 |
| Trunkline | 24     | 609.6 | 574.6 | 17.48 |
|           | 32     | 812.8 | 766.2 | 23.31 |
|           | 36     | 914.4 | 862.0 | 26.22 |

| Fluid | Flowline Injection Point |      |        | Trunkline Injection Point |      |        |
|-------|--------------------------|------|--------|---------------------------|------|--------|
|       | Mass Rate                | T    | P      | Mass Rate                 | T    | P      |
|       | [kg/s]                   | [°C] | [bara] | [kg/s]                    | [°C] | [bara] |
| GD    | 35                       | 80   | 400    | 85                        | 60   | 200    |
| GCL   | 15                       | 120  | 350    | 95                        | 65   | 250    |
| GCW   | 70                       | 80   | 400    | 175                       | 60   | 300    |
| MO    | 50                       | 65   | 300    | 250                       | 60   | 200    |

|                          | Trunkline Arrival Point |
|--------------------------|-------------------------|
|                          | [bara]                  |
| Onshore Arrival Pressure | 40                      |
|                          | 60                      |
|                          | 80                      |

## *Basic Data – Creation of simulation cases*

---

- Starting from the data reported in the previous slide, 36 simulation cases were created:
  - Three couples of different diameters for flowline and trunkline were selected, namely 8" & 24", 10" & 32" and 12" & 36";
  - Three different arrival pressures were imposed at the Onshore Terminal, namely 40 bara, 60 bara and 80 bara;
  - Four fluids were defined for the scope of the study;
  - Total number of simulation cases equal to 36 (nine cases for each fluid).
- Steady state analysis was performed for all the 36 cases.
- Transient analysis was performed only for several cases, using the results of steady state analysis as its starting point.
- In order to obtain plausible results, it was decided to generate identical input model for both software. Input model was first created by OLGA (version 6), and then converted to LedaFlow input file (version 1.3).

# Steady State Analysis

## Sum up & Results

## Steady State Analysis - Legend

---

1: Case **GC-L\_RP60\_D8&24** is to be interpreted in the following way:

- **GC-L** stands for the fluid, in this case **Light Gas Condensate**.
- **RP60** stands for the Onshore Receiving Pressure, in this case equal to **60 bara**.
- **D8&24** stands for a Flowline having the diameter of 8" ND and a Trunkline having the diameter of 24" ND.

2: **The deviation** , expressed in **percentage** and used to compare the Steady State results, has been calculated using the following equation:

$$dev[\%] = \frac{x_{i,LED}^{SS} - x_{i,OLGA}^{SS}}{x_{i,OLGA}^{SS}} \cdot 100$$

3. **The Flow Regime** is identified according to codes given in the following Table:

| Physical Flow Regime |                 |
|----------------------|-----------------|
| Value                | Description     |
| 0 - 1                | Stratified flow |
| 2                    | Annular flow    |
| 3                    | Slug flow       |
| 4                    | Bubble flow     |

## Single Phase Gas Flow (GD) - Steady State Sum up

### **Compared Variables** (Flowline and Trunkline):

1. Inlet and Outlet Pressure; Pressure Drop (DP).
2. Inlet and Outlet Temperature.
3. Gas Mass Content.

### **Remarks:**

- All cases have reached the steady state condition.
- For single phase (gas phase) simulations: no significant differences are reported for the analyzed variables.

## Single Phase Gas Flow (GD) - Steady State Results

| GD             | FLOWLINE |        |               |             |        |                    |
|----------------|----------|--------|---------------|-------------|--------|--------------------|
| Case           | Pressure |        |               | Temperature |        | Mass Fluid Content |
|                | Inlet    | Outlet | Pressure Drop | Inlet       | Outlet | Gas                |
| GD_RP40_D8&24  | -0.09%   | -0.17% | 0.06%         | -0.04%      | -0.03% | 0.12%              |
| GD_RP40_D10&32 | -0.08%   | -0.29% | 0.37%         | -0.05%      | -0.08% | 0.14%              |
| GD_RP40_D12&36 | 0.00%    | -0.38% | 1.24%         | 0.00%       | -0.29% | 0.23%              |
| GD_RP60_D8&24  | -0.08%   | -0.14% | 0.04%         | -0.04%      | -0.03% | 0.14%              |
| GD_RP60_D10&32 | -0.07%   | -0.21% | 0.31%         | -0.04%      | -0.09% | 0.18%              |
| GD_RP60_D12&36 | 0.00%    | -0.24% | 1.06%         | 0.00%       | -0.20% | 0.24%              |
| GD_RP80_D8&24  | -0.07%   | -0.12% | 0.03%         | -0.03%      | -0.02% | 0.15%              |
| GD_RP80_D10&32 | -0.05%   | -0.15% | 0.27%         | -0.03%      | -0.08% | 0.22%              |
| GD_RP80_D12&36 | 0.00%    | -0.15% | 0.91%         | 0.00%       | -0.14% | 0.25%              |

| GD             | TRUNKLINE |        |               |             |        |                    |
|----------------|-----------|--------|---------------|-------------|--------|--------------------|
| Case           | Pressure  |        |               | Temperature |        | Mass Fluid Content |
|                | Inlet     | Outlet | Pressure Drop | Inlet       | Outlet | Gas                |
| GD_RP40_D8&24  | 0.00%     | -0.04% | 0.02%         | -0.08%      | -2.98% | -0.05%             |
| GD_RP40_D10&32 | 0.01%     | -0.06% | 0.11%         | -0.01%      | -0.98% | -0.02%             |
| GD_RP40_D12&36 | 0.02%     | -0.07% | 0.22%         | 0.04%       | -0.76% | -0.02%             |
| GD_RP60_D8&24  | 0.01%     | -0.02% | 0.03%         | -0.08%      | -1.92% | -0.04%             |
| GD_RP60_D10&32 | 0.01%     | -0.02% | 0.11%         | -0.05%      | -0.73% | -0.03%             |
| GD_RP60_D12&36 | 0.01%     | -0.03% | 0.21%         | -0.04%      | -0.60% | -0.03%             |
| GD_RP80_D8&24  | 0.01%     | -0.01% | 0.03%         | -0.09%      | -1.35% | -0.04%             |
| GD_RP80_D10&32 | 0.01%     | -0.01% | 0.10%         | -0.08%      | -0.60% | -0.04%             |
| GD_RP80_D12&36 | 0.01%     | -0.02% | 0.20%         | -0.08%      | -0.52% | -0.03%             |

## Single Phase Oil Flow (MO) - Steady State Sum up

---

### Compared Variables (Flowline and Trunkline):

1. Inlet and Outlet Pressure; Pressure Drop (DP).
2. Inlet and Outlet Temperature.
3. Liquid Mass Content.

### Remarks:

- All cases have reached the steady state condition.
- For single phase (liquid phase) simulations: no significant differences are reported for the analyzed variables.

## Single Phase Oil Flow (MO) - Steady State Results

| MO             | FLOWLINE |        |               |             |        |                    |
|----------------|----------|--------|---------------|-------------|--------|--------------------|
| Case           | Pressure |        |               | Temperature |        | Mass Fluid Content |
|                | Inlet    | Outlet | Pressure Drop | Inlet       | Outlet | Oil                |
| MO_RP40_D8&24  | -0.04%   | -0.07% | -0.01%        | 0.01%       | -0.04% | 0.27%              |
| MO_RP40_D10&32 | 0.02%    | 0.02%  | 0.01%         | 0.00%       | -0.05% | 0.31%              |
| MO_RP40_D12&36 | 0.06%    | 0.12%  | 0.02%         | -0.01%      | -0.03% | 0.27%              |
| MO_RP60_D8&24  | -0.04%   | -0.06% | -0.01%        | 0.01%       | -0.04% | 0.27%              |
| MO_RP60_D10&32 | 0.01%    | 0.02%  | 0.01%         | 0.00%       | -0.05% | 0.31%              |
| MO_RP60_D12&36 | 0.05%    | 0.09%  | 0.02%         | -0.01%      | -0.06% | 0.27%              |
| MO_RP80_D8&24  | -0.04%   | -0.06% | -0.01%        | 0.01%       | -0.03% | 0.27%              |
| MO_RP80_D10&32 | 0.01%    | 0.01%  | 0.01%         | 0.00%       | -0.02% | 0.31%              |
| MO_RP80_D12&36 | 0.04%    | 0.06%  | 0.02%         | 0.00%       | 0.03%  | 0.27%              |

| MO             | TRUNKLINE |        |               |             |        |                    |
|----------------|-----------|--------|---------------|-------------|--------|--------------------|
| Case           | Pressure  |        |               | Temperature |        | Mass Fluid Content |
|                | Inlet     | Outlet | Pressure Drop | Inlet       | Outlet | Oil                |
| MO_RP40_D8&24  | -0.04%    | -0.01% | -0.05%        | -0.05%      | 0.00%  | -0.003%            |
| MO_RP40_D10&32 | 0.04%     | 0.01%  | 0.10%         | -0.07%      | -0.16% | -0.002%            |
| MO_RP40_D12&36 | 0.08%     | 0.01%  | 0.25%         | -0.07%      | -0.21% | -0.002%            |
| MO_RP60_D8&24  | -0.03%    | -0.01% | -0.05%        | -0.05%      | 0.00%  | -0.003%            |
| MO_RP60_D10&32 | 0.03%     | 0.01%  | 0.09%         | -0.06%      | -0.15% | -0.002%            |
| MO_RP60_D12&36 | 0.06%     | 0.01%  | 0.26%         | -0.07%      | -0.19% | -0.001%            |
| MO_RP80_D8&24  | -0.04%    | 0.00%  | -0.06%        | -0.05%      | 0.00%  | -0.003%            |
| MO_RP80_D10&32 | 0.02%     | 0.01%  | 0.07%         | -0.06%      | -0.18% | -0.002%            |
| MO_RP80_D12&36 | 0.04%     | 0.01%  | 0.23%         | -0.06%      | -0.21% | -0.001%            |

## Light Gas Condensate (GC-L) - Steady State Sum up

---

### Compared Variables (for both Flowline and Trunkline):

1. Inlet and Outlet Pressure; Pressure Drop (DP).
2. Inlet and Outlet Temperature.
3. Gas and Liquid Mass Content.
4. Gas and Liquid Velocities.
5. Flow Regime.

### Remarks:

- Four cases (out of nine) have not reached the steady-state condition (Unstable cases for at least one software are shown in the following table **in red**).
- No significant differences for **Pressure, Temperature, Gas Content, Gas Velocity**. Minor differences are noted when comparing **DP**.

## Light Gas Condensate (GC-L) - Steady State Results

| GC-L | FLOWLINE                   |              |              |               |              |               |                    |                |
|------|----------------------------|--------------|--------------|---------------|--------------|---------------|--------------------|----------------|
|      | Case                       | Pressure     |              |               | Temperature  |               | Mass Fluid Content |                |
|      |                            | Inlet        | Outlet       | Pressure Drop | Inlet        | Outlet        | Gas                | Oil            |
|      | GC-L_RP40_D8&24            | 0.37%        | 1.33%        | -4.31%        | 0.11%        | -0.36%        | 1.00%              | -48.75%        |
|      | GC-L_RP40_D10&32           | -0.51%       | 0.51%        | -5.64%        | -0.16%       | 0.39%         | 0.20%              | -40.57%        |
|      | GC-L_RP40_D12&36           | 2.03%        | 0.20%        | 12.90%        | -0.06%       | -0.72%        | 1.99%              | 42.60%         |
|      | <b>GC-L_RP60_D8&amp;24</b> | <b>0.32%</b> | <b>1.00%</b> | <b>-3.37%</b> | <b>0.10%</b> | <b>-0.12%</b> | <b>0.82%</b>       | <b>-50.19%</b> |
|      | GC-L_RP60_D10&32           | -0.55%       | 0.25%        | -5.53%        | -0.18%       | 0.29%         | 0.08%              | -42.09%        |
|      | GC-L_RP60_D12&36           | 2.12%        | 0.02%        | 16.65%        | 0.03%        | -0.72%        | 1.70%              | 62.38%         |
|      | GC-L_RP80_D8&24            | 0.18%        | 0.60%        | -2.32%        | 0.05%        | 0.02%         | 0.57%              | -52.43%        |
|      | GC-L_RP80_D10&32           | 0.48%        | 0.05%        | 3.54%         | -0.33%       | -0.13%        | 0.61%              | 40.45%         |
|      | GC-L_RP80_D12&36           | 2.47%        | -0.07%       | 21.85%        | 0.19%        | -0.88%        | 1.63%              | 86.02%         |

| GC-L | TRUNKLINE                  |              |               |               |              |               |                    |                |
|------|----------------------------|--------------|---------------|---------------|--------------|---------------|--------------------|----------------|
|      | Case                       | Pressure     |               |               | Temperature  |               | Mass Fluid Content |                |
|      |                            | Inlet        | Outlet        | Pressure Drop | Inlet        | Outlet        | Gas                | Oil            |
|      | GC-L_RP40_D8&24            | 1.35%        | -0.02%        | 2.34%         | 1.71%        | -1.45%        | 1.57%              | -22.29%        |
|      | GC-L_RP40_D10&32           | 0.56%        | -0.03%        | 1.86%         | 9.22%        | -0.51%        | 0.48%              | -11.25%        |
|      | GC-L_RP40_D12&36           | 0.27%        | -0.04%        | 1.41%         | 15.68%       | -0.42%        | 0.17%              | -1.39%         |
|      | <b>GC-L_RP60_D8&amp;24</b> | <b>1.01%</b> | <b>-0.01%</b> | <b>2.41%</b>  | <b>1.13%</b> | <b>-1.08%</b> | <b>1.17%</b>       | <b>-19.80%</b> |
|      | GC-L_RP60_D10&32           | 0.25%        | -0.01%        | 1.47%         | 3.57%        | -0.42%        | 0.18%              | -3.53%         |
|      | GC-L_RP60_D12&36           | 0.06%        | -0.02%        | 0.66%         | 4.62%        | -0.36%        | -0.07%             | 8.91%          |
|      | GC-L_RP80_D8&24            | 0.61%        | 0.01%         | 1.96%         | 0.56%        | -0.78%        | 0.68%              | -16.53%        |
|      | GC-L_RP80_D10&32           | 0.05%        | -0.01%        | 0.54%         | 1.09%        | -0.36%        | -0.05%             | 5.23%          |
|      | GC-L_RP80_D12&36           | -0.09%       | -0.01%        | -1.22%        | 1.00%        | -0.34%        | -0.05%             | -4.38%         |

- Unstable cases for at least one software are shown in red.


## Light Gas Condensate (GC-L) - Steady State Results

---


The following readings have been taken at the most significant points of the pipeline:

- Temperature and Pressure – at four significant points:
  - Flowline Inlet
  - Flowline Arrival
  - Trunkline Inlet
  - Trunkline Arrival
- Velocity – at two significant points:
  - Flowline Arrival
  - Trunkline Arrival
- Accumulated Liquid (Oil and Water) has been recorded along both the Flowline and Trunkline.



# Light Gas Condensate (GC-L) - Steady State Results





# Light Gas Condensate (GC-L) – Steady State Results



# Light Gas Condensate (GC-L) –Steady State Results



# Light Gas Condensate (GC-L) –Steady State Results



## Multiphase Flow (GC-W) - Steady State Sum up

---

### Compared Variables (for both Flowline and Trunkline):

1. Inlet and Outlet Pressure; Pressure Drop (DP).
2. Inlet and Outlet Temperature.
3. Oil, Gas and Water Mass Content.
4. Oil and Water Velocities.
5. Flow Regime.

### Remarks:

- Four cases (out of nine) have not reached the steady state condition (Unstable cases for at least one software are shown in the following table **in red**).
- No significant differences for **Pressure, Temperature, Gas Content, Gas Velocity, Oil Volume Fraction**. Minor differences are noted when comparing **DP**.

## Multiphase Flow (GC-W) - Steady State Results

| GC-W | FLOWLINE                    |              |              |               |               |              |                    |               |               |
|------|-----------------------------|--------------|--------------|---------------|---------------|--------------|--------------------|---------------|---------------|
|      | Case                        | Pressure     |              |               | Temperature   |              | Mass Fluid Content |               |               |
|      |                             | Inlet        | Outlet       | Pressure Drop | Inlet         | Outlet       | Gas                | Oil           | Water         |
|      | GCW-M_RP40_D8&24            | -1.24%       | 0.65%        | -3.04%        | -0.28%        | 0.10%        | 0.96%              | -1.86%        | 18.80%        |
|      | GCW-M_RP40_D10&32           | -1.70%       | -1.44%       | -1.99%        | -0.19%        | -0.13%       | -2.88%             | -0.53%        | 21.49%        |
|      | GCW-M_RP40_D12&36           | -0.07%       | -2.76%       | 3.80%         | -0.04%        | -0.32%       | -1.94%             | -0.05%        | 18.44%        |
|      | <b>GCW-M_RP60_D8&amp;24</b> | <b>0.44%</b> | <b>2.56%</b> | <b>-1.89%</b> | <b>-0.25%</b> | <b>0.13%</b> | <b>-1.62%</b>      | <b>-1.01%</b> | <b>21.96%</b> |
|      | GCW-M_RP60_D10&32           | -0.59%       | -1.03%       | 0.04%         | -0.23%        | -0.13%       | -5.65%             | 1.24%         | 15.91%        |
|      | GCW-M_RP60_D12&36           | -0.06%       | -1.95%       | 3.16%         | -0.35%        | -0.17%       | -7.46%             | 0.91%         | 34.73%        |
|      | GCW-M_RP80_D8&24            | 0.77%        | 2.24%        | -1.10%        | -0.23%        | 0.14%        | -3.61%             | -1.06%        | 23.83%        |
|      | GCW-M_RP80_D10&32           | -0.50%       | -1.28%       | 0.82%         | -0.37%        | 0.03%        | -10.13%            | 1.18%         | 26.70%        |
|      | GCW-M_RP80_D12&36           | -0.19%       | -1.52%       | 2.45%         | -0.25%        | -0.21%       | -11.53%            | 1.17%         | 37.60%        |

| GC-W | TRUNKLINE                   |              |               |               |               |               |                    |               |               |
|------|-----------------------------|--------------|---------------|---------------|---------------|---------------|--------------------|---------------|---------------|
|      | Case                        | Pressure     |               |               | Temperature   |               | Mass Fluid Content |               |               |
|      |                             | Inlet        | Outlet        | Pressure Drop | Inlet         | Outlet        | Gas                | Oil           | Water         |
|      | GCW-M_RP40_D8&24            | 0.78%        | -0.02%        | 1.47%         | -0.72%        | -0.05%        | -5.25%             | -0.98%        | 23.29%        |
|      | GCW-M_RP40_D10&32           | -1.25%       | -0.03%        | -4.11%        | -2.16%        | -0.26%        | -5.78%             | 3.55%         | -0.01%        |
|      | GCW-M_RP40_D12&36           | -2.54%       | 0.03%         | -9.99%        | -1.98%        | -0.29%        | -5.95%             | 5.49%         | -8.62%        |
|      | <b>GCW-M_RP60_D8&amp;24</b> | <b>2.67%</b> | <b>-0.01%</b> | <b>6.82%</b>  | <b>-0.81%</b> | <b>-0.20%</b> | <b>-8.00%</b>      | <b>-0.12%</b> | <b>31.08%</b> |
|      | GCW-M_RP60_D10&32           | -0.92%       | -0.01%        | -4.44%        | -2.47%        | -0.25%        | -8.53%             | 3.62%         | 3.30%         |
|      | GCW-M_RP60_D12&36           | -1.81%       | -0.01%        | -10.08%       | -3.18%        | -0.32%        | -8.44%             | 6.33%         | -10.01%       |
|      | GCW-M_RP80_D8&24            | 2.33%        | 0.01%         | 7.76%         | -0.76%        | -0.14%        | -13.59%            | 0.56%         | 33.67%        |
|      | GCW-M_RP80_D10&32           | -1.20%       | -0.01%        | -7.85%        | -2.15%        | -0.23%        | -14.10%            | 4.33%         | 4.73%         |
|      | GCW-M_RP80_D12&36           | -1.44%       | -0.01%        | -10.62%       | -4.37%        | -0.32%        | -10.42%            | 5.81%         | -8.55%        |

- Unstable cases for at least one software are shown in red.


## Multiphase Flow (GC-W) - Steady State Results

---


The following readings have been taken at the most significant points of the pipeline:

- Temperature and Pressure – at four significant points:
  - Flowline Inlet
  - Flowline Arrival
  - Trunkline Inlet
  - Trunkline Arrival
  
- Velocity – at two significant points:
  - Flowline Arrival
  - Trunkline Arrival
  
- Accumulated Liquid (Oil and Water) has been recorded along both the Flowline and Trunkline.



# Multiphase Flow (GC-W) - Steady State Results




# Multiphase Flow (GC-W) - Steady State Results



# Multiphase Flow (GC-W) - Steady State Results



# Multiphase Flow (GC-W) - Steady State Results



**Transient Analysis**

**Sum up & Results**

## Transient Analysis – Analyzed Cases

---

| TRANSIENT  | DRY GAS  | GAS CONDENSATE LIGHT  |
|--|--|---|
| <p><b>Shut-down and Depressurization</b><br/>(Blow-down)</p> | <p>Flowline: 8"<br/>Trunkline: 24"<br/>Receiving Pressure: 60 barg</p> | <p>Flowline: 10"<br/>Trunkline: 32"<br/>Receiving Pressure: 40 barg</p> |

### Shut-down

Initial Condition: Relevant Steady State.  
 Valves closure speed: 1 inch/second.  
 Simulation end: Liquid content stabilization along both lines.

### Depressurization (Blow-down)

Initial Condition: Shut-down condition estimated by LEDA has been used as initial condition for both codes.  
 Leak opening speed: 1 min  
 Leak diameter: 1" (25.4 mm) for flowline; 4" (101.6 mm) for trunkline.  
 Leak discharge coefficient: 0.84.  
 Simulation end: Pressure equalization with the ambient.

**F/L (8inch) and T/L (24inch)**

**Shut-down Simulation**

**Dry Gas**

## Shut-down – Dry Gas: Sum up

---

### Compared Variables (for both Flowline and Trunkline):



1. Pressure along the pipelines at the beginning of transient analysis (at the instant corresponding to 2.5% of the total time required to reach steady state conditions) and at the final instant of the shut-down i.e. when steady state condition has been achieved (t=100%).
2. Temperature along the pipelines during the shut-down (2.5% and 10% of the total time required to reach steady state condition).
3. The deviation for both pressure and temperature, expressed in **percentage** and calculated using the following equation:

$$dev[\%] = \frac{x_{i,j}^{LED} - x_{i,j}^{OLGA}}{x_{i,j}^{OLGA}} \cdot 100$$


### Remarks:

- No significant differences were noted for **Pressure** and **Temperature** along both Flowline and Trunkline.


# Flowline Shut-down – Dry Gas - COMPARISON





# Flowline Shut-down – Dry Gas - COMPARISON



# Trunkline Shut-down – Dry Gas - COMPARISON



# Trunkline Shut-down – Dry Gas - COMPARISON



**Flowline (8inch)**

**Depressurization Simulation**

**Dry Gas**

## Flowline Depressurization (B/D) – Dry Gas: Sum up

---



### Compared variables are:

1. Leak Flowrate vs. time at the Flowline discharge (Outlet).
2. Pressure vs. time at the Flowline discharge (Outlet).
3. Temperature vs. time at the Flowline far end (Inlet).
4. Temperature vs. time at the Flowline discharge end (Outlet).


### Remarks:

- No significant differences were noted for **Leak Flowrate** and **Pressure**.
- Different behavior is noted for **Temperature at the flowline far end**: LEDA indicates a cooling effect (represented by low temperature), which is not reported by OLGA.
- No significant differences were noted **at the pipeline discharge**.


# Flowline Depressurization (B/D) – Dry Gas: COMPARISON



# Flowline Depressurization (B/D) – Dry Gas: COMPARISON



# Flowline Depressurization (B/D) – Dry Gas: COMPARISON



**Trunkline (24inch)**  
**Depressurization Simulation**  
**Dry Gas**

## Trunkline Depressurization (B/D) of Dry Gas: Sum up

---



### Compared Variables:

1. Leak Flowrate vs. time at the Trunkline discharge (Outlet).
2. Pressure vs. time at the Trunkline discharge (Outlet).
3. Temperature vs. time at the Trunkline far end (Inlet).
4. Temperature vs. time at the Trunkline discharge end (Outlet).
5. Temperature vs. Trunkline profile when Pressure equalization with the ambient was completed.


### Remarks:

- No significant differences were noted for **Leak Flowrate** and **Pressure**.
- Different behavior is noted for **Temperature both at Trunkline discharge** and **far end extreme**: OLGA indicates a wider temperature variations with respect to LEDA.


# Trunkline Depressurization (B/D) – Dry Gas: COMPARISON




# Trunkline Depressurization (B/D) – Dry Gas: COMPARISON



# Trunkline Depressurization (B/D) – Dry Gas: COMPARISON



# Trunkline Depressurization (B/D) – Dry Gas: COMPARISON



**F/L (10 inch) and T/L (32 inch)**

**Shut-down Simulation**

**Light Gas Condensate**

## Shut-down - Light Gas Condensate: SUM-UP

---

### Compared Variables (for both Flowline and Trunkline):



1. Pressure along the pipelines at the beginning of transient analysis (the instant corresponding to 2.5% of the total time foreseen to reach steady state condition) and at the final instant of the shut-down i.e. when steady state condition has been achieved (t=100%).
2. Temperature along the pipelines during the shut-down (2.5% and 10% of the total time required to reach steady state condition).
3. Gas and liquid Hold-up along the pipelines at the end of the shut-down i.e. when steady condition have been achieved.
4. The deviation for both pressure and temperature, expressed in **percentage and** calculated using the following equation:

$$dev[\%] = \frac{x_{i,j}^{LED} - x_{i,j}^{OLGA}}{x_{i,j}^{OLGA}} \cdot 100$$


### Remarks:

- No significant differences were noted for **Pressure and Temperature** along both Flowline and Trunkline.
- No significant differences were noted for **Gas and Liquid Mass Content** profiles along both Flowline and Trunkline.


# Flowline Shut-down – Light Gas Condensate: COMPARISON





# Flowline Shut-down – Light Gas Condensate: COMPARISON




# Flowline Shut-down – Light Gas Condensate: COMPARISON




# Trunkline Shut-down – Light Gas Condensate: COMPARISON



# Trunkline Shut-down – Light Gas Condensate: COMPARISON



# Trunkline Shut-down – Light Gas Condensate: COMPARISON



**Flowline (10 inch)**

**Depressurization Simulation**

**Light Gas Condensate**

## Flowline Depress. (B/D) – Light Gas Cond: Sum up

---



### Compared Variables:

1. Leak vs. time at the Flowline discharge (Outlet).
2. Pressure vs. time at the Flowline discharge (Outlet).
3. Pressure along the Flowline at  $t=T_{min}$  and at the 5% of the total time necessary for depressurization with the deviation.
4. Gas and liquid hold-up along the Flowline at the final instant of the depressurization.
5. Temperature along the Flowline approximately 1 hour after leak opening.
6. Temperature vs. time at the Flowline far end (Inlet).
7. Temperature vs. time at the Flowline discharge (Outlet).


### Remarks:

- No significant differences were noted for **Leak Flowrate, Pressure and Hold-up**.
- Minor differences were noted for **Temperature at the pipeline discharge** : within 1 °C.
- Different behavior is noted for the **Temperature at the pipeline far end**: LEDA indicates a cooling effect (lower temperature) which is not reported by OLGA. The **Temperature profile** indicates that the low temperature is related to the gas phase (LEDA). OLGA reports a temperature that is a mean value between the oil and gas phase temperature reported by LEDA.


# Flowline Depress. (B/D) – Light Gas Cond: COMPARISON




# Flowline Depress. (B/D) – Light Gas Cond: COMPARISON




# Flowline Depress. (B/D) – Light Gas Cond: COMPARISON




# Flowline Depress. (B/D) – Light Gas Cond: COMPARISON



## Flowline Depress. (B/D) – Light Gas Cond: COMPARISON



# Flowline Depress. (B/D) – Light Gas Cond: COMPARISON



**Trunkline (32 inch)**  
**Depressurization Simulation**  
**Light Gas Condensate**

## Trunkline Depress. (B/D) – Light Gas Cond.: Sum up

---



### Compared Variables:

1. Leak Flowrate vs. time at the Trunkline discharge (Outlet).
2. Pressure vs. time at the Trunkline discharge (Outlet).
3. Pressure along the Trunkline at  $t=T_{min}$  and at the 5% of the total time necessary for depressurization, with the deviation.
4. Gas and liquid Hold-up along the Trunkline at the final instant of the depressurization.
5. Temperature along the Trunkline approximately 1 hour after leak opening.
6. Temperature vs. time at the Trunkline far end (Inlet).
7. Temperature vs. time at the Trunkline discharge (Outlet).



### Remarks:

- No significant differences were noted for **Leak Flowrate**, **Pressure** and **Hold-up**.
- No practical difference on **Temperature at the pipeline discharge end**.
- Different behavior for the **Temperature along the Trunkline at the pipeline far end extreme**: OLGA indicates a cooling effect (lower temperature) which is not reported by LEDA.


# Trunkline Depress. (B/D) – Light Gas Cond.: COMPARISON




# Trunkline Depress. (B/D) – Light Gas Cond.: COMPARISON




# Trunkline Depress. (B/D) – Light Gas Cond.: COMPARISON




# Trunkline Depress. (B/D) – Light Gas Cond.: COMPARISON



# Trunkline Depress. (B/D) – Light Gas Cond.: COMPARISON



# Trunkline Depress. (B/D) – Light Gas Cond.: COMPARISON



## Comparison Sum up

## Conclusions – Summary of Main Issues

---

1. Input file conversion from Olga to LedaFlow (and vice-versa) was not found to be a smooth process, therefore extra attention should be paid when performing such activity.
2. Results of **Steady State** analysis for single phase fluids have shown a good match as reported in the following table. Not all the cases reached the steady state condition.
3. Results of **Steady State** and **Transient State** analysis for multiphase fluids have shown a good match when it comes to **pressure and temperature**, whereas differences were noted in **accumulated liquid and velocities**, as reported in the following table.
4. Significant difficulties were faced in input and run comparable cases for **Pigging, Ramp up and Turn down** (originally planned in the scope of the present work as important operating scenario) which resulted in abandoning of such comparison.

## Conclusions – Summary of Main Issues

| Simulations  | Pipeline System  | Operation Condition           | Operation Details                     | Main Findings   |
|--------------|--|-------------------------------|---------------------------------------|---|
| Steady State | F/L and T/L:<br>- 8" and 24"<br>- 10" and 32"<br>- 12" and 36"<br>Receiving Pressure:<br>40; 60 and 80 bar | Single Phase transport        | Gas                                   | - Focus on P, T and Mass Content.<br>- <b>No significant difference to be reported.</b>   |
|              |  |                               | Liquid                                |   |
|              |  | Multiphase Transport          | Gas-condensate                        | - Focus on P, T, Gas and Liquid Content, Gas and Liquid Velocity, Flow Regime.<br>- <b>No significant differences to be reported on: P, T, Gas Content and Velocity, Flow Regime.</b><br>- <b>Differences to be reported on: Liquid Accumulation and Velocity along the pipelines.</b>    |
|              |  |                               | Gas-condensate + Water                |   |
| Transients   | F/L: 8"<br>T/L: 24"<br>Rec. P: 60 bar  | Shut-down                     | Single Phase (Gas)                    | - Focus on P, T, Gas and Liquid Content at the end of the shut-down.<br>- <b>No significant difference to be reported.</b>  |
|              |  |                               | Multiphase Transport (Gas Condensate) |   |
|              | F/L: 10"<br>T/L: 32"<br>Rec. P: 40 bar   | Depressurization (from 1 end) | Single Phase (Gas)                    | - Focus on P, T, Gas and Liquid Content and Depressurization Flowrate.<br>- <b>No significant difference to be reported on: P, T, Depressurization Flowrate and Mass content vs. time.</b><br>- <b>Differences to be reported on Minimum Temperature, mainly at the pipeline far end.</b> |
|              |  |                               | Multiphase Transport (Gas Condensate) |   |

**Indications on  
Possible Further Developments**

## Further Works

---

1. To progress in the comparison of these two Codes considering other typical transient simulations for pipeline systems such as:
  - Turn-down and Ramp-up analysis, to investigate liquid inventory vs. flowrate, liquid accumulation velocity, onset of fluid-dynamic instabilities, slugging at the outlet.
  - Re-pressurization and re-start analysis, starting from the already performed simulations of shut-down and depressurization.
  - Pigging analysis, possibly including simple sweeping pigging (single pig) and more complex pigging (launch of liquid batches in between two pigs).
2. To share and discuss the results obtained through the present work with other Entities as a contribution to the comparison between Olga and LedaFlow.